

# FRANKLIN CO RWD 1 Consumer Confidence Report – 2019 Covering Calendar Year – 2018



This brochure is a snapshot of the quality of the water that we provided last year. Included are the details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies. If you would like to observe the decision-making process that affect drinking water quality, please call CATHY DUDERSTADT at 785-242-5508.

Our drinking water is supplied from another water system through a Consecutive Connection (CC). Your water comes from :

Buyer Name	Seller Name
FRANKLIN CO RWD 1	CITY OF WELLSVILLE
FRANKLIN CO RWD 1	CITY OF OTTAWA
FRANKLIN CO RWD 1	MIAMI CO RWD 2
CITY OF WELLSVILLE	CITY OF BALDWIN CITY
CITY OF BALDWIN CITY	CITY OF LAWRENCE

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) included rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in sources water before we treat it include:  
Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, livestock operations and wildlife.  
Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.  
Pesticides and herbicides, which may come from a variety of sources such as storm water run-off, agriculture, and residential users.  
Radioactive contaminants, which can be naturally occurring or the result of mining activity.  
Organic contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also come from gas stations, urban storm water run-off, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulation which limits the amount of certain contaminants in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Our water system is required to test a minimum of 2 samples per month in

accordance with the Total Coliform Rule for microbiological contaminants. Coliform bacteria are usually harmless, but their presence in water can be an indication of disease-causing bacteria. When coliform bacteria are found, special follow-up tests are done to determine if harmful bacteria are present in the water supply. If this limit is exceeded, the water supplier must notify the public.

## Water Quality Data

The following tables list all of the drinking water contaminants which were detected during the 2018 calendar year. The presence of these contaminants does not necessarily indicate the water poses a health risk. Unless noted, the data presented in this table is from the testing done January 1- December 31, 2018. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old. **The bottom line is that the water that is provided to you is safe.**

## Terms & Abbreviations

**Maximum Contaminant Level Goal (MCLG):** the "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLGs allow for a margin of safety.

**Maximum Contaminant Level (MCL):** the "Maximum Allowed" MCL is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Secondary Maximum Contaminant Level (SMCL):** recommended level for a contaminant that is not regulated and has no MCL.

**Action Level (AL):** the concentration of a contaminant that, if exceeded, triggers treatment or other requirements.

**Treatment Technique (TT):** a required process intended to reduce levels of a contaminant in drinking water.

**Maximum Residual Disinfectant Level (MRDL):** the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Non-Detects (ND):** lab analysis indicates that the contaminant is not present.

**Parts per Million (ppm)** or milligrams per liter (mg/l)

**Parts per Billion (ppb)** or micrograms per liter (µg/l)

**Picocuries per Liter (pCi/L):** a measure of the radioactivity in water.

**Millirems per Year (mrem/yr):** measure of radiation absorbed by the body.

**Monitoring Period Average (MPA):** An average of sample results obtained during a defined time frame, common examples of monitoring periods are monthly, quarterly and yearly.

**Nephelometric Turbidity Unit (NTU):** a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person. Turbidity is not regulated for groundwater systems.

**Running Annual Average (RAA):** an average of sample results obtained over the most current 12 months and used to determine compliance with MCLs.

**Locational Running Annual Average (LRAA):** Average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters.

Testing Results for: FRANKLIN CO RWD 1

Disinfection Byproducts	Monitoring Period	Highest RAA	Range (low/high)	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	2018	40	28 - 42	ppb	60	0	By-product of drinking water disinfection
TTHM	2018	58	44 - 54	ppb	80	0	By-product of drinking water chlorination

Lead and Copper	Monitoring Period	90 <sup>th</sup> Percentile	Range (low/high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2015 - 2017	0.086	0.0068 - 0.19	ppm	1.3	0	Corrosion of household plumbing
LEAD	2015 - 2017	2.2	1.6 - 2.2	ppb	15	0	Corrosion of household plumbing

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

During the 2018 calendar year, we had the below noted violation(s) of drinking water regulations.

Compliance Period	Analyte	Comments
10/1/2018 - 12/31/2018	TTHM	MONITORING, ROUTINE (DBP), MAJOR
10/1/2018 - 12/31/2018	TOTAL HALOACETIC ACIDS (HAA5)	MONITORING, ROUTINE (DBP), MAJOR

Some or all of our drinking water is supplied from another water system. The table below lists all of the drinking water contaminants, which were detected during the 2018 calendar year from the water systems that we purchase drinking water from.

Regulated Contaminants	Collection Date	Water System	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
ARSENIC	2/14/2018	CITY OF LAWRENCE	1.9	1 - 1.9	ppb	10	0	Erosion of natural deposits
ATRAZINE	6/13/2018	CITY OF OTTAWA	2	2	ppb	3	3	Runoff from herbicide used on row crops
BARIUM	2/14/2018	CITY OF LAWRENCE	0.096	0.023 - 0.096	ppm	2	2	Discharge from metal refineries
CHROMIUM	5/2/2018	CITY OF LAWRENCE	3	1.3 - 3	ppb	100	100	Discharge from steel and pulp mills
FLUORIDE	4/4/2018	CITY OF OTTAWA	0.64	0.56 - 0.64	ppm	4	4	Natural deposits; Water additive which promotes strong teeth.
NITRATE	5/9/2018	MIAMI CO RWD 2	0.86	0.71 - 0.86	ppm	10	10	Runoff from fertilizer use
PICLORAM	5/10/2018	CITY OF LAWRENCE	0.2	0.2	ppb	500	500	Herbicide runoff
SELENIUM	8/15/2018	CITY OF LAWRENCE	11	2.2 - 11	ppb	50	50	Erosion of natural deposits

Secondary Contaminants	Collection Date	Water System	Highest Value	Range (low/high)	Unit	SMCL
ALKALINITY, TOTAL	5/10/2018	CITY OF LAWRENCE	132	44.7 - 132	MG/L	300
ALUMINUM	2/14/2018	CITY OF LAWRENCE	100	0.003 - 100	MG/L	0.05
BROMIDE	8/15/2018	CITY OF LAWRENCE	0.061	0.018 - 0.061	MG/L	0.05
CALCIUM	5/2/2018	CITY OF LAWRENCE	51	38 - 51	MG/L	200
CALCIUM	8/15/2018	CITY OF LAWRENCE	58	27 - 58	MG/L	
CHLORIDE	5/2/2018	CITY OF LAWRENCE	130	21 - 130	MG/L	250
CHROMIUM, HEX	11/1/2018	CITY OF LAWRENCE	2.1	0.1 - 2.1	UG/L	
CONDUCTIVITY @ 25 C UMHOS/CM	5/2/2018	CITY OF LAWRENCE	880	320 - 880	UMHO/CM	1500
CORROSION	5/2/2018	CITY OF LAWRENCE	0.28	-0.051 - 0.28	LANG	0
DESETHYLATRAZINE	6/13/2018	CITY OF OTTAWA	0.43	0.43	UG/L	
HARDNESS, CALCIUM MAGNESIUM	1/3/2018	CITY OF LAWRENCE	62	1.9 - 62	MG/L	
HARDNESS, TOTAL (AS CaCO3)	11/1/2018	CITY OF LAWRENCE	170	120 - 170	MG/L	400
IRON	5/9/2018	MIAMI CO RWD 2	0.02	0.02	MG/L	0.3
MAGNESIUM	1/3/2018	CITY OF LAWRENCE	15	0.5 - 15	MG/L	150
METOLACHLOR	6/13/2018	CITY OF OTTAWA	3	3	ppb	
MOLYBDENUM, TOTAL	8/15/2018	CITY OF LAWRENCE	6.1	4.2 - 6.1	UG/L	
NICKEL	5/2/2018	CITY OF LAWRENCE	0.0049	0.0012 - 0.0049	MG/L	0.1
ORTHOPHOSPHATE	2/12/2014	CITY OF LAWRENCE	1.1	0.06 - 1.1	MG/L	
PH	5/10/2018	CITY OF LAWRENCE	8.8	8 - 8.8	PH	8.5
PHOSPHORUS, TOTAL	5/2/2018	CITY OF LAWRENCE	0.86	0.11 - 0.86	MG/L	5
POTASSIUM	8/15/2018	CITY OF LAWRENCE	13	3.6 - 13	MG/L	100
SILICA	8/15/2018	CITY OF LAWRENCE	14	0.5 - 14	MG/L	50
SODIUM	5/2/2018	CITY OF LAWRENCE	110	14 - 110	MG/L	100
STRONTIUM	8/15/2018	CITY OF LAWRENCE	310	220 - 310	UG/L	
SULFATE	5/2/2018	CITY OF LAWRENCE	130	22 - 130	MG/L	250
TDS	5/2/2018	CITY OF LAWRENCE	470	200 - 470	MG/L	500
UV ABSORBANCE @254 NM	1/7/2014	CITY OF LAWRENCE	0.088	0.051 - 0.088	CM-1	
VANADIUM, TOTAL	5/10/2018	CITY OF LAWRENCE	8.5	3.7 - 8.5	UG/L	
ZINC	5/9/2018	MIAMI CO RWD 2	0.01	0.01	MG/L	5

**Please Note: Because of sampling schedules, results may be older than 1 year.**

During the 2018 calendar year, the water systems that we purchase water from had the below noted violation(s) of drinking water regulations.

Water System	Type	Category	Analyte	Compliance Period
CITY OF WELLSVILLE	LEAD CONSUMER NOTICE (LCR)	RPT	LEAD & COPPER RULE	12/30/2017 - 11/5/2018
MIAMI CO RWD 2	MONITORING, SOURCE (LT2), MAJOR	MON	E. COLI	7/2/2018 - 7/6/2018
CITY OF BALDWIN CITY	MONITORING, ROUTINE (DBP), MAJOR	MON	CDS_DBP_TOTALS	7/1/2018 - 9/30/2018